

Water lead test - July 2017

July 26, 2017

Suburban Laboratories, Inc. **Analytical Method:**
EPA 200.8

Samples Taken: 7/15/2017

Data Rcvd:
7/26/2017

NOTE: There are two readings for each location.

The first reading is from water sitting overnight.

The second is from water run after thirty seconds.

Green means lead levels were Not Detected

**Yellow means lead levels were between 2.0 - 4.9
 µg/L. This level is posted on the website.**

**Red means the levels were above 5 µg/L. This information was sent to parents
 via e-mail within two days after receiving the data.**

<u>Sample Location Description</u>	<u>Fixture Type</u>	<u>Sample Volume (mL)</u>	<u>Concentration (µg/L)</u>
Parlor Girls Bathroom	Right sink	250	0
Parlor Girls Bathroom	Right sink	250	0
Parlor	Refridgerated Drinking Fountain	250	0
	Refridgerated Drinking Fountain	250	0
Kindergarten - Bathroom	sink	250	0
Kindergarten - Bathroom	sink	250	0
Kindergarten	Drinking Fountain	250	0
	Drinking Fountain	250	0
Kindergarten	sink	250	0
Kindergarten	sink	250	0
Pre-K (4) - Bathroom	sink	250	0
Pre-K (4) - Bathroom	sink	250	0
Pre-K (4)	Drinking Fountain	250	0
	Drinking Fountain	250	0
Pre-K (4)	sink	250	0
Pre-K (4)	sink	250	0
Pre-S (3) - Bathroom	sink	250	0
Pre-S (3) - Bathroom	sink	250	0

Pre-S (3)	Drinking Fountain	250	0	
Pre-S (3)	Drinking Fountain	250	0	
Pre-S (3)	sink	250	0	
Pre-S (3)	sink	250	0	
Outside Office	Refridgerated Drinking Fountain	250	0	
Outside Office	Refridgerated Drinking Fountain	250	0	
Office bathroom	sink	250	0	
Office bathroom	sink	250	0	
AD Bathroom	sink	250	0	
AD Bathroom	sink	250	0	
Boys Locker Room	Left sink	250	0	
Boys Locker Room	Left sink	250	0	
Boys Locker Room	Right sink	250	0	
Boys Locker Room	Right sink	250	0	
Girls Locker Room	Left sink	250	0	
Girls Locker Room	Left sink	250	0	
Girls Locker Room	Right sink	250	2.18	
Girls Locker Room	Right sink	250	0	
Kitchen	Ice Machine	250	0	
Kitchen	Ice Machine	250	0	
Kitchen	Kitchen Coffee Urn	250	21.1	
Kitchen	Kitchen Coffee Urn	250	3.57	
Kitchen	sink - 3 Bay	250	16.6	
Kitchen	sink - 3 Bay	250	0	
Kitchen	sink - Handwashing	250	13.6	
Kitchen	sink - Handwashing	250	0	
Kitchen	sink - Alcove	250	43.6	
Kitchen	sink - Alcove	250	0	
Kitchen - Bathroom	sink	250	15.7	
Kitchen - Bathroom	sink	250	0	
Sacristry	sink	250	0	
Sacristry	sink	250	0	
Fellowship Kitchenette	sink	250	0	
Fellowship Kitchenette	sink	250	0	
2nd Floor Boys Bathroom	Left sink	250	0	2.15
2nd Floor Boys Bathroom	Left sink	250	0	
2nd Floor Boys Bathroom	Right sink	250	12.6	
2nd Floor Boys Bathroom	Right sink	250	0	
2nd Floor Girls Bathroom	Left sink	250	5.97	
2nd Floor Girls Bathroom	Left sink	250	0	
2nd Floor Girls Bathroom	Middle sink	250	4.23	

2nd Floor Girls Bathroom	Middle sink	250	0
2nd Floor Girls Bathroom	Right sink	250	2.67
2nd Floor Girls Bathroom	Right sink	250	0
First Grade	sink	250	0
First Grade	sink	250	0
First Grade	Drinking Fountain	250	0
First Grade	Drinking Fountain	250	0
Fellowship	Refridgerated Drinking Fountain	250	0
Fellowship	Refridgerated Drinking Fountain	250	0
Fellowship Boys Bathroom	Left sink	250	5.98
Fellowship Boys Bathroom	Left sink	250	0
Fellowship Boys Bathroom	Right sink	250	3.67
Fellowship Boys Bathroom	Right sink	250	0
Fellowship Girls Bathroom	Left sink	250	0
Fellowship Girls Bathroom	Left sink	250	0
Fellowship Girls Bathroom	Right sink	250	0
Fellowship Girls Bathroom	Right sink	250	0
Boys Bathroom Outside Bowling Alley	sink	250	0
Boys Bathroom Outside Bowling Alley	sink	250	0
Girls Bathroom Outside Bowling Alley	sink	250	0
Girls Bathroom Outside Bowling Alley	sink	250	0
Outside Bowling Alley	Refridgerated Drinking Fountain	250	0
Outside Bowling Alley	Refridgerated Drinking Fountain	250	0
Parlor Boys Bathroom	sink	250	0
Parlor Boys Bathroom	sink	250	0
Parlor Girls Bathroom	sink	250	0
Parlor Girls Bathroom	sink	250	0
2nd Floor Between Bathrooms	Refridgerated Drinking Fountain	250	5.14
2nd Floor Between Bathrooms	Refridgerated Drinking Fountain	250	0
Staff Restrooms - Male	sink	250	2.73
Staff Restrooms - Male	sink	250	0
Staff Restrooms - Female	sink	250	2.48
Staff Restrooms - Female	sink	250	0
Staff Sink	sink	250	0
Staff Sink	sink	250	0
Science/Art Room	sink	250	0
Science/Art Room	sink	250	0

3rd Floor Boys Bathroom	Left sink	250	0
3rd Floor Boys Bathroom	Left sink	250	0
3rd Floor Boys Bathroom	Right sink	250	0
3rd Floor Boys Bathroom	Right sink	250	0
3rd Floor Girls Bathroom	Left sink	250	0
3rd Floor Girls Bathroom	Left sink	250	0
3rd Floor Girls Bathroom	Right sink	250	0
3rd Floor Girls Bathroom	Right sink	250	0
	Refridgerated		
3rd Floor Outside Bathrooms	Drinking	250	0
	Fountain		
	Refridgerated		
3rd Floor Outside Bathrooms	Drinking	250	0
	Fountain		
Extended Care - Kitchenette	sink	250	0
Extended Care - Kitchenette	sink	250	0